

Resultados da monitorização da qualidade da onda de tensão

Ano 2023	Sakthi (STI 220kV) - 220kV																																																			
Característica\Semanas	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52
Amplitude	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	
Desequilíbrio	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green
Distorção Harmónica	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green
Frequência	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green	Green
Tremulação (flicker)	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow

Limites segundo o Regulamento da Qualidade de Serviço:

Muito Alta Tensão (MAT):	Amplitude -5% e +5% da tensão declarada (Uc) para 95% do tempo de medição
	Desequilíbrio 2% do valor eficaz da componente inversa das tensões para 95% do tempo
	Distorção Harmónica O valor da distorção harmónica total (THD) deverá ser inferior a 4% para 95% do tempo
	Frequência -1% e +1% de 50Hz - Para 99,5% do tempo de medição de uma semana.
	Tremulação (Flicker) Plt e Pst: 1% para 95% do tempo de medição

Alta Tensão (AT):	Amplitude -5% e +5% da tensão declarada (Uc) para 95% do tempo de medição
	Desequilíbrio 2% do valor eficaz da componente inversa das tensões para 95% do tempo
	Distorção Harmónica O valor da distorção harmónica total (THD) deverá ser inferior a 8% para 95% do tempo
	Frequência -1% e +1% de 50Hz - Para 99,5% do tempo de medição de uma semana.
	Tremulação (Flicker) Plt: 1% para 95% do tempo de medição

Legenda:

S/M	Sem medição	Green	Muito alta qualidade	≤ -100%	Abaixo do limite
⊗	Medição incompleta	Light Green	Alta qualidade	-66%	
		Yellow	Qualidade normal	-33%	
		Orange	Baixa qualidade	0% No limite	Acima do limite
		Pink	Muito baixa qualidade	33%	
		Red	Muitíssima baixa qualidade	66%	
				≥ 100%	

Índice Normalizado

$$i_{(p,l,f)}(\%) = \left(\frac{n_{(p,l,f)}}{l_{(p)}} - 1 \right) \times 100$$

Resultados da monitorização da qualidade da onda de tensão

Cavas de tensão (NP EN 50160)

Ponto de Medição					Período de medição		Tensão residual	Número / Duração (milissegundos)					Observações / motivo da medição
Zona	Nível de tensão (V)		Identificação	Fixo / Móvel	DE	A		10 < t <= 200	200 < t <= 500	500 < t <= 1000	1000 < t <= 5000	5000 < t <= 60000	
	Un	Uc					10 > u >= 80	80 > u >= 70	70 > u >= 40	40 > u >= 5	5 > u		
	220000	231000	STI 220kV	F	2023-01-02 00:00:00.0	2023-12-31 23:59:00.0	30	2	1	0	0		
							11	0	0	0	0		
							4	0	0	0	0		
							0	0	0	0	0		
							0	0	0	0	0		

Sobretensões (NP EN 50160)

Ponto de Medição					Período de medição		Amplitude	Número / Duração (milissegundos)			Observações / motivo da medição
Zona	Nível de tensão (V)		Identificação	Fixo / Móvel	DE	A		10 < t <= 500	500 < t <= 5000	5000 < t <= 60000	
	Un	Uc					u >= 120	120 > u > 110			
	220000	231000	STI 220kV	F	2023-01-02 00:00:00.0	2023-12-31 23:59:00.0	0	0	0		
							0	0	0		